

From: Rand Crafts
To: Milka Radulovic
Date: Wednesday, June 04, 2003 8:45 AM
Subject: Re: IPP-CO Major Mod

We have no information that VOC will change in any way that is different than what we calculated (using a combination of AP-42 and industry-specific EPRI factors, and testing) for the dense pack project. For CO such was not the case. We did have information (from vendors) that would indicate that CO could be different after OFA was added.

Rand Crafts
Intermountain Power Service Corp
rand-c@ipsc.com
435-864-6494
435-864-0994 Fax

>>>> "Milka Radulovic" <MilkaR@utah.gov> Tuesday, June 03, 2003 11:33:19 AM >>>>

Rand,
we discussed this earlier the info in the NOI - table with the emissions change with no increase in VOC. You gave me a reason for it but I still think there will be a change in VOC emissions. Please call when you can to talk about this.

Thanks
Milka